



Woltman Turbo - Water MeterModel WT **II**

A family of compact size Woltman water meters with field interchangeable lightweight measuring units.

Features

- High accuracy, low loss of head and high immunity against abrasive media in the water due to double magnetic coupling. This unique construction leaves only one moving element, the impeller, in contact with water. The next moving components, including the worm & worm wheel, are kept in a sealed, dry compartment and have no contact with any abrasive media present in the water.
- Tungsten carbide impeller shaft tips & bearings for negligible wear in Heavy Duty use are standard.
- A wide selection of sealed, magnetically coupled registers, adaptable to 2G and 3G technologies, as well as different electrical output versions, single or multiple, are available.
- Registers are: Stainless steel/glass encapsulated and guaranteed against fogging.

Applications


Water supply networks, agricultural application and industrial use.

Available Sizes

2" -12" (50mm - 300mm)

Standards

ISO 4064, AWWA, EEC



Solution Technical Specifications

Maximum Working Pressure	Standard - 16 bar Upon request – 25 bar				
Maximum Liquid Temperature	60°C				
Body	Cast iron, polyester coated. Optional - bronze (AWWA standard)				
Connection	Flanges according to ISO, BS 10 AWWA or others				



WT Ⅲ type dial





Performance data

Mode	l WT II	Qmax Maximum	Qn ISO 4064	Qn Nominal	Qt Transitional	Qmin Minimum	Starting Flow	Maximum register	Smallest readable	Accuracy between	Accuracy between	
Nominal Size		flowrate	(m³/h)	Flowrate	Flowrate	Flowrate	(m³/h)	capacity	unit	Qmax & Qt	Qt & Qmin	
mm	inch	(m ³ /h)	(m ² /n)		(m³/h)	(m ³ /h)	(m³/h)		(m³)	(liter)		
50	2	100	15	50	1	0.45	0.30	10 ⁶	1			
65	2 ¹ / ₂	100	25	70	1.4	0.75	0.4	10 ⁶	1			
80	3	170	40	120	1.4	0.8	0.4	10 ⁶	1			
100	4	300	60	230	2	1.5	0.6	10 ⁷	10	±2%	±5%	
150	6	410	150	260	3.5	2.5	1.0	10 ⁷	10			
200	8	730	250	450	15	7	2	10 ⁸	100			
250	10	1400	400	750	13	10	6	10 ⁸	100]		
300	12	2000	600	1000	40	11.5	7	10 ⁸	100			


Dimensions

) 65 2 ¹ / ₂	80	100	150			
2 ¹ / ₂			150	200	250	300
	3	4	6	8	10	12
0 200	230	250	300	350	450	500
5 185	200	200	283	340	406	460
4 228	234	250	310	338	438	465
84	90	106	130	158	258	330
2 13	15.5	19	35	47	75	95
	4 228	4 228 234 0 84 90	4 228 234 250 0 84 90 106	4 228 234 250 310 0 84 90 106 130	4 228 234 250 310 338 0 84 90 106 130 158	4 228 234 250 310 338 438 0 84 90 106 130 158 258





Mead Loss Curve



New Proof of the Proof of the

- The water meter may be installed in any position. For non-horizontal positions the flow shall be upwards.
- The meter shall be full of water while operating.
- Prior to installation of a meter, the pipeline shall be thoroughly flushed.
- Straight pipe section of the same diameter D as the meter, having length of 5D and 2D shall be installed upstream and downstream of the meter respectively.